



Sprinkler Express Permits



Are you looking for a speedy sprinkler permit?

Here's what you can do!



- Prince William County Fire Marshal's Office offers an option to obtain permits for mercantile and business use groups with construction modifications to ten sprinkler heads or less.



What is in it for me?

- Fire Sprinkler plans are not required to be submitted for review, but need to be on job-site for inspection.
- The process is intended to speed the permit process for contractors who are doing relatively minor sprinkler changes.



How do I Qualify?

- Must obtain a fire protection permit
- Sprinkler plans must show scope of work during inspection.
 - ✓ *Scope of work must be clearly defined on the plans and permit.*
 - ✓ *Explanations for all sprinkler modifications must be included.*
- May add or relocate a combined total of ten(10) heads or less
 - ✓ *Sprinkler heads must be the same type, k-factor, temperature, style, etc.*
- Sprinkler installation must comply with **NFPA 13**.
- Sprinkler head spacing and pipe must be consistent with existing design.
- No modifications to the sprinkler cross-mains or risers are allowed.
- New hangers must comply with the spacing requirement in **NFPA 13**.
- Customers must complete fire inspections.

For more information please visit
our website below or contact us at

<http://www.pwcgov.org/FMOPlanReview>

Fire Marshal's Office
Prince William County
Department of Fire & Rescue
5 County Complex Court
Prince William, VA 22192
703-792-6360