



COUNTY OF PRINCE WILLIAM

5 County Complex Court, Suite 120, Prince William, Virginia 22192-5308
(703) 792-6930 Metro 631-1703 Fax: (703) 792-5285

**DEPARTMENT OF
DEVELOPMENT
SERVICES**
Division of
Building Development

BUILDING OFFICIAL INTERPRETATION 2015-09

March 09, 2020

CODE/EDITION: VIRGINIA UNIFORM STATEWIDE BUILDING CODE/2015

**SECTION(S): ICC A117.1-2009 Accessible and Usable Buildings and
Facilities**

QUESTION:

1. Is a single toilet restroom required to have a self-closing door?

ANSWERS

1. No.

ICC A117.1-2009, Section 604.9 Wheelchair Accessible Compartment is not applicable to a single toilet restroom. A "compartment" is a toilet stall created by toilet partitions within a multi-toilet restroom. A single toilet restroom is not a "compartment."

Eric M. Mays, P.E.
Building Official