



BUILDING INSPECTION CERTIFICATION

Version **2025-05-01**

<p style="text-align: center;">Architect/Engineer Data</p> <p>Name: _____</p> <p>Address: _____</p> <p>Phone #: _____</p>	<p style="text-align: center;">Project/Site Data</p> <p>Building Permit #: _____ Owner/Builder: _____</p> <p>Site Address: _____</p> <p>Project/Subdivision: _____ Section: _____ Lot #: _____</p> <p>Soil Category: <input type="checkbox"/> I <input type="checkbox"/> II <input type="checkbox"/> III</p>
---	--

✓	ITEM	DATE	INSPECTOR
FOOTING & FOUNDATION			
	Controlled Fill placed under the Site Permit*		
	Controlled Fill placed under this Building Permit*		
	Footings: On Grade Design Soil Bearing = 1500 psf		
	Footings: On Grade Design Tested Soil Bearing > 1500 psf*		
	Footings: On Controlled Fill*		
	Pile foundation		
	Pier foundation		
	Deck/porch		
	Concrete wall/steel rebar		
	Backfill (below grade seal)		
	• Drain Mechanical		
	• Drain-Gravity/Daylight		
	• Wall Soil Lateral Pressure Design < 60 psf*		
	• Wall Soil Lateral Pressure Design = 60 psf with MH or Inorganic CL*		
	• Wall Soil Lateral Pressure Design = 60 psf with SC, ML-CL, or better		
	• Dampproofing		
	• Waterproofing		
MASONRY			
	Masonry Construction		
	Masonry Hearth		

✓	ITEM	DATE	INSPECTOR
SLAB on grade (OG), controlled fill (CF)*, structural(S)			
	Grade level OG <input type="checkbox"/> , CF <input type="checkbox"/> , S <input type="checkbox"/>		
	Basement OG <input type="checkbox"/> , CF <input type="checkbox"/> , S <input type="checkbox"/>		
	Garage level OG <input type="checkbox"/> , CF <input type="checkbox"/> , S <input type="checkbox"/>		
	Stoop/porch OG <input type="checkbox"/> , CF <input type="checkbox"/> , S <input type="checkbox"/>		
	Areaway OG <input type="checkbox"/> , CF <input type="checkbox"/> , S <input type="checkbox"/>		
	Elevated Level		
	Footings/Slab Insulation		
STEEL			
	Structural Steel		
	Cold Rolled Steel		
FIRE PROTECTION			
	Fire Rated Assembly (BDD Policy 1.6.7)		
	Through Penetration Firestop System**		
	Sprayed cementitious**		
	Mineral Fiber**		
	Other:		
CONCRETE ENCASED GROUNDING ELECTRODE			
	Minimum 20' of 1/2" rebar		
	Minimum of 20' of #4 copper conductor		
OTHER INSPECTIONS			
	Exterior Insulation Finish System (EIFS) **		
	Foundation Structural Repair		
	Structural repair(s)		
	Other:		

***Professional Engineer's certification with soil data and test results attached.**

****Must attach ICC or NES Research Report and/or manufacturer's instructions for installation and inspection**

At the time of this inspection, all items inspected were in accordance with the County approved building plans and the Virginia Uniform Statewide Building Code; a copy of the required building permit was posted on the construction site.

Architect/Engineer Seal

Signature: _____ Date: _____

By checking this box, I agree to electronically signing this form