



Residential Duct Leakage Test Certification

Version 2025-05-01

HOME DATA

MODEL _____

PERMIT NUMBER _____

SITE ADDRESS _____

SQUARE FEET OF CONDITION FLOOR AREA _____

TEST RESULTS

ROUGH-IN TEST RESULTS WITHOUT AIR HANDLER: _____ CFM

ROUGH-IN TEST RESULTS WITH AIR HANDLER INSTALLED: _____ CFM

POST-CONSTRUCTION RESULTS: _____ CFM

TEST RESULTS FOR DUCTS LOCATED WITHIN THE BUILDING THERMAL ENVELOPE: _____ CFM

Rough-in Test: The total leakage shall be less than or equal to 4 cubic feet per minute (113.3 L/min) per 100 square feet (9.29 m2) of conditioned floor area where the air handler is installed at the time of the test. Where the air handler is not installed at the time of the test, the total leakage shall be less than or equal to 3 cubic feet per minute (85 L/min) per 100 square feet (9.29 m2) of conditioned floor area.

Post Construction Test: Total leakage shall be less than or equal to 4 cubic feet per minute (113.3 L/ min) per 100 square feet (9.29 m2) of conditioned floor area.

Test for Ducts within the Thermal Envelope: Where all ducts and air handlers are located entirely within the building thermal envelope, total leakage shall be less than or equal to 8.0 cubic feet per minute (226.6 L/min) per 100 square feet (9.29 m2) of conditioned floor area.

I Certify that these Duct Leakage Rates are Accurate and Determined using Standard Duct Testing Practices

Company Name: _____

Technician (Print): _____

Technician Signature: _____ Date: _____

By checking this box, I agree to electronically signing this form.